

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7151-0026:208 Page 1 of 1

CATEGORY: Boxes/Pull Stations - Hazardous Locations

LISTEE: Simplex, *100 Simplex Drive, Westminster, MA 01441-0001
Contact: Paul Mattern (978) 731-8542

DESIGN: Models 2099-9765, -9766, -9767 and -9799 pull stations with SIMPLEX Model 2098-9036 Barrier for use in Class I, II, or III, Division 1, Group A through G hazardous locations. Noncoded, addressable or pre-signal option. Model 2081-9036 barrier shall be mounted in non-hazardous location and supplies intrinsically safe levels to models 2099-9765 and -9766. Refer to listee's data sheet for detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number electrical rating and FM label.

APPROVAL: Listed as pull stations for indoor use with separately listed compatible control units. Pull stations located in hazardous locations shall employ SIMPLEX Model 2098-9036 Barrier. Barrier Model 2098-9036 (CSFM Listing No. 7300-0026:180) to be mounted in a non-hazardous location.

*Rev. 06-21-2000



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 8, 2002

*Listing Expires **June 30, 2003***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager